



Lead Consumer Notice CWS TCEQ Form 20680a

**Community Public Water Systems
Texas Commission on Environmental Quality**

PWS ID #: TX 1700803 DATE: 02-Nov-2023

PWS NAME: New Danville Community

Our public water supply system is required to periodically collect tap water samples to determine the lead levels in our system. Your residence was selected for this monitoring as part of our system's sampling plan. This notice is provided to you with the analytical results of the tap water sample collected at your home.

Sample address: LCR0010- 10951 Shepard Hill Rd. Apt 7A Willis, TX 77318

Sample collection date: 27-Sep-2023

Analytical Lead result, in mg/L (milligrams per liter): <0.00500

Definitions

Action Level (AL): The action level is a concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a public water system must follow. The lead action level is 0.015 mg/L. *Maximum contaminant level goal (MCLG):* The level of a contaminant in drinking water below which there is no expected health risk. MCLGs allow a margin of safety. The MCLG for lead is 0.

What are the health effects of lead and how can I reduce my exposure?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. New Danville Community is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap until the water is noticeably colder before using the water and using only cold water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [EPA Safewater for Lead](#). When replacing your bathroom or kitchen faucet, consider a "lead-free" faucet that meets NSF/ANSI Standard 61 Annex G, which is less than 0.25% lead by weight.

Who can I contact at my water system for more information?

Phone number at our public water supply system: (936) 236-6828

E-mail address at our public water supply system: randy.smyth@newdanville.org